


GRAIN SIZE DISTRIBUTION

AASHTO T-88



BORING ID	DEPTH	% COARSE MATERIAL	% SAND	% SILT	% FINES	% CLAY	USCS
■ B-01	6				39.7		SC
◆ B-01	13.5	21.5	10.2		68.3		CL
▲ B-01	23.5	22.7	8.4		68.9		CL

GRAIN SIZE			
	■	◆	▲
D₆₀		0.032	0.033
D₃₀			
D₁₀			

	■	◆	▲
Sieve	% Finer	Sieve	% Finer
#200	39.67	3/8 in	100.00
		#4	92.76
		#10	78.51
		#20	77.27
		#40	75.69
		#100	72.08
		#200	68.29
		3/8 in	100.00
		#4	97.38
		#10	77.25
		#20	76.34
		#40	75.20
		#100	72.06
		#200	68.87

SOIL DESCRIPTION	
■	CLAYEY SAND (SC)
◆	SANDY LEAN CLAY (CL)
▲	SANDY LEAN CLAY (CL)

COEFFICIENTS			
	■	◆	▲
C_c			
C_u			

REMARKS	
■	A-4 (0)
◆	A-7-6 (17)
▲	A-6 (9)

PROJECT: EQUIS Geotech Demo

SITE: 123 Discovery Road
Seattle, WA




PROJECT NUMBER: EQUISGEOTECH

CLIENT: EarthSoft
Bellevue, Wa

GRAIN SIZE DISTRIBUTION

AASHTO T-88



COARSE MATERIAL	SAND		SILT OR CLAY
	coarse	fine	

BORING ID	DEPTH	% COARSE MATERIAL	% SAND	% SILT	% FINES	% CLAY	USCS
●	B-01	33.5	8.0	27.9	64.1	64.1	CL

GRAIN SIZE			
	●		
D₆₀	0.057		
D₃₀	0.007		
D₁₀			

	●	Sieve	% Finer	Sieve	% Finer	Sieve	% Finer
	●	3/8 in	100.00				
		#4	98.87				
		#10	92.05				
		#20	86.95				
		#40	82.67				
		#100	72.80				
		#200	64.14				

SOIL DESCRIPTION	
●	SANDY LEAN CLAY (CL)

COEFFICIENTS			
	●		
C_c			
C_u			

REMARKS	
●	A-6 (6)

PROJECT: EQUIS Geotech Demo

SITE: 123 Discovery Road
Seattle, WA



125 S. Alcaniz St. Pensacola FL

PROJECT NUMBER: EQUISGEOTECH

CLIENT: EarthSoft
Bellevue, Wa